



Swimming Pool Final Inspection Checklist

Bureau of Water

Permit Number:	Facility Name:	Date:		
District:	Address:	Time:		
Pre-Inspection Items		Yes	No	N/A
1.	Pipe Approved			
2.	Required Letters			
3.	Fill Water Approved			
4.	Sewer Connection Approved			
General Construction Permit Items				
5.	Pool dimensions			
6.	Shower at major entrance points (as per plans)			
7.	Fence or barrier (A&E min. 6', other types min. 4', all gates self closing and can be locked)			
8.	Protective barrier provided on any elevated structure or second floor balcony within 10' horizontally of pool			
9.	Overhead wiring (if not in conduit must be 20' away from pool horizontally)			
10.	Pool wall and floor (smooth, non-slip, single light color)			
11.	Deck (meets minimum width requirements, non-slip, sloped 1/4" to 5/8" per foot away from pool, adequately drains to waste)			
12.	6" glazed frost proof tile at water line			
13.	No ledges or seats in main body of pool			
14.	Adequate handhold from coping or deck			
15.	Fill spout location			
16.	Fill water backflow prevention (2 X diameter of spout above pool rim or double check valve assembly with proper test results verified)			
17.	Hose bibb with ASSE 1024 residential dual check or equiv. (location min. 10" above deck)			
Pool Interior & General Area				
18.	Depth markers (correct to nearest 1/2', 4" numerals, include feet or ft, max. 15' intervals, 2' increments of depth, wall & coping, white background color and a total of 12" of white tile shall be included as a part of the depth marker at waterline, no diving tile included in deck depth markers at pools requiring no diving signs)			
19.	All appurtenances as per plans (skimmer/gutter, return, main drain, vacuums)			
20.	Lifeline if max. depth exceeds 5'6" (marked with permanent non-slip dark color tile stripe min. 4", max. 6", min. 3/4" rope, floats 5" by 6" and a max. of 5' apart)			
21.	Ladders (secure and in place, min. three tread design, non-slip)			
22.	Handrails (secure, extends over bottom step)			
23.	Steps (marked in min. 2" dark colored, non-slip stripe or tile)			
24.	Water level (middle of skimmer or at gutter lip edge)			
25.	Overflow line (6" air gap or in-line check valve)			
26.	Adequate deck lighting, GFI per NEC			
27.	Underwater lights with GFI			
28.	No light fixtures over the water surface			
29.	Drinking water fountain as per plans (within 50' of pool, GFI if applicable)			
30.	Diving board requirements as per plans			
31.	Trash can			
32.	Bathhouse facilities (proximity, light, vent, drain, no interconnection, shower, water closet, lavatory, toilet paper, liquid or powder soap, towel dispenser or blower hand dryers, shatter-resistant mirrors) or minimum toilet facility			

Purpose: This form is to be used by State employees conducting final inspections on public swimming pools.

ITEM BY ITEM INSTRUCTIONS FOR COMPLETING THIS FORM:

Enter the permit number, district in which the facility is located, facility name and address inspection date and time of inspection at the top of the form.

Check the appropriate box for each line item: Yes, No, or Not Applicable.

Enter the chemical levels at time of inspection.

Enter any comments concerning the inspection in the comment section.

The contractor's representative, owner's representative and DHEC representative performing the inspection must sign the bottom of the form.

Check Yes or Not Applicable to indicate if the facility must call for a reinspection or if facility has passed the final inspection and may operate when a permit to operate is issued.

Office Mechanics and Filing: The white copy is filed in the Recreational Waters File Room according to facility permit number, a Xerox copy is kept in the District office. The canary copy is given to the contractor's representative. The pink copy is given to the owner's representative.